

1. The plan and the information contained herein is privileged and is given solely to the intended recipient for the specific purpose in which the plan is given. No part of the plan shall be reproduced or circulated to others under any circumstances.
2. The information of the watermains on this plan is valid as at date plotted and is given without any liability for any error, mis-statement or omission therein.
3. Position of watermains and the boundary lines of the water catchment indicated on this plan are approximate only. Smaller submains and connections to customers' premises/properties are not indicated. Trial holes must be carried out to determine the exact alignments and levels of all watermains before commencement of any earthworks.
4. The cost of diversions, if required, of any watermains shall be borne by owner / developer. For watermains of 500mm diameter and above, these are our vital trunk mains and diversions should be avoided unless absolutely necessary. Owner / developer shall determine by means of trial holes the exact alignment and levels of all existing watermains during the design stage and let PUB know whether they are affected by the proposed work so that PUB can advise whether diversion is required. If deem necessary by PUB, the affected watermains shall be diverted and the cost of diversion shall be borne by owner / developer. The cost of diversion shall be finalized upon confirmation on the length of watermains affected.
5. All other necessary precautions must be taken to safeguard and to avoid the damaged to the watermains. The cost of repairs to any watermains damaged as a result of work carried out is to be borne by party which causes the damage. The party will also be billed for the repair of the mains and the estimated quantities of water lost from the damaged mains. The party will also be required to indemnify PUB against all losses and claims arising from damage to watermains.
6. Please inform PUB 24-hour Call Centre at Tel No 1800-CALL PUB (1800-2255782) immediately in the event of damaged to watermain.


Type of Water Mains:

PUB Water Mains
NEWater Mains
Industrial Water Mains
Raw Water Mains

Dia
NW - Dia
IW - Dia
RW - Dia

Legend:

Existing Water Mains	
Proposed Water Mains	
Water Mains Under Construction	
Abandoned Water Mains	
Water Chamber	
Double Pillar Hydrant	
Ground Pillar Hydrant	
Triple Pillar Hydrant	
PUB Installation	
Drain Line	
The Proposed Site is outlined in YELLOW	



DONE BY: Generated by PCCSATE: 06/04/2023

